



License No. 42193 to mark a commodity with the Standards Mark

The Standards Institution of Israel (SII), in accordance with the powers vested in it by article 11(b) of the Standards law 1953, hereby grants permission to:

RAV-BARIACH (08) INDUSTRIES LTD

Hakhshmal 17 St. ,Ashkelon ,Israel

to place the Standards Mark on the commodities covered by the standard:
Fire Door And Smoke Door Assemblies: Swinging Fire Doors

(list of types attached)

**These commodities are produced in conformity with the requirements of the
Israel Standard No. 1212 Part 1 Edition May 2003 Amendment 1, 2, 3, 4, 5, 6**

This license has been granted subject to the terms of the Standards Regulation (standard mark and supervision sign) 1982, and the terms that the License Committee has determined, which constitute an integral part of this license. This license does not detract from any obligation, or other order, imposed by law on the abovementioned commodities

This certificate remains the property of SII. Its continued validity may be verified via scanning the barcode or via the SII website www.sii.org.il.

This license is valid until 31/12/2025

Date of License : 01/01/2025



R.N 514160530

Dr. Gilad Golub
CEO



The standards Institution of Israel
42 Chaim Levanon St,
Tel-Aviv 6997701



Annex A: License No. 42193

Factory: RAV-BARIACH (08) INDUSTRIES LTD

Commodities: Fire Door And Smoke Door Assemblies: Swinging Fire Doors

Models:

1. SINGLE LEAF METAL FIRE DOOR WITH/WITHOUT WINDOW, MODEL 408 MAXIMUM DIMENSIONS OF RECTANGLE: WIDTH 1,032 MM, HEIGHT 2,200 MM, DESIGNATION: FIRE DOOR 3/4 HOUR (1/2 / 3/4 / 1)
2. DOUBLE LEAF FIRE DOOR (WITHOUT WINDOW) MODEL 808 DESIGNATION: FIRE DOOR 1/2 HOUR (1/2 / 1/2 / 1/2) DIMENSIONS OF MOVING LEAF: HEIGHT 2,185 MM, WIDTH 1.180 MM RECTANGLE: HEIGHT 2,300 MM, WIDTH 2,200 MM
3. DOUBLE WING FIRE DOOR, WITH WINDOWS, MODEL 808 DESIGNATION: FIRE DOOR 1 HOUR (1/2 / 1 / 1) MAXIMUM DIMENSIONS: MOVABLE WING: HEIGHT 2185 MM, WIDTH 1180 MM FRAME: HEIGHT 2198 MM, WIDTH 2197 MM
4. DOUBLE WING FIRE DOOR, WITH/WITHOUT WINDOWS MODEL FW90 DESIGNATION: FIRE DOOR 1½ HOUR (1/2 / 1¼ / 1½) MAXIMUM DIMENSIONS: MOVABLE WING: HEIGHT 2200 MM, WIDTH 1140 MM FRAME: HEIGHT 2359 MM, WIDTH 2394

This license is valid until 31/12/2025

Date of License : 01/01/2025



R.N 514160530

Dr. Gilad Golub
CEO



The standards Institution of Israel
42 Chaim Levanon St,
Tel-Aviv 6997701



Annex A: License No. 42193

Factory: RAV-BARIACH (08) INDUSTRIES LTD

Commodities: Fire Door And Smoke Door Assemblies: Swinging Fire Doors

5. DOUBLE WING FIRE DOOR, WITH/WITHOUT WINDOWS,
MODEL FW30 DESIGNATION: FIRE DOOR ½ HOUR
(½ / 1½ / ½) MAXIMUM DIMENSIONS: MOVABLE WING:
HEIGHT 2250 MM, WIDTH 1140 MM
FRAME: HEIGHT 2300 MM, WIDTH 2360 MM
6. Fire door single winged with/without window type
FWB Designation 3/4 hour, class (½ / ¾ / 1½)
:Maximal Dimensions wing - Width 2255 mm, Height
980 mm rectangle - Width 2307 mm, Height 1054 mm
7. Single wing metal fire door, with/without
without window, Model FWI-870 Designation: ¾ hour
(½ / 1½ / ¾)
Frame dimensions: width 1210 mm, height 2400 mm
Wing dimensions: width 1140 mm, height 2200 mm
8. Single wing fire door, Model 408 m, designation:
fire door ½ hour (½ / ½ / ½) Maximum frame
dimensions: width 1030 mm, height 2270 mm
Maximum wing dimensions: width 960 mm, height
2210 mm

This license is valid until 31/12/2025

Date of License : 01/01/2025



R.N 514160530

Dr. Gilad Golub
CEO



The standards Institution of Israel
42 Chaim Levanon St,
Tel-Aviv 6997701



Annex A: License No. 42193

Factory: RAV-BARIACH (08) INDUSTRIES LTD

Commodities: Fire Door And Smoke Door Assemblies: Swinging Fire Doors

9. Double wing monitored fire door, with/without windows, Model FWI-870, Designation: one hour (1 / 1 / ½), Maximum dimensions: Frame: width 2359 mm, height 2295 mm
Movable wing: width 1140 mm, height 2200 mm
10. Double wing fire door, with/without windows, Model FW30 improved Designation, one and a half a half hours ½ / 2 / 1½) Maximum frame dimensions
Movable wing maximum dimensions: width 1140 mm, height 2050
11. SINGLE wing fire door, without windows, model FE15 designation: fire door 1 hour (1/2 / 1 / 1)
Maximum dimension: FRAME dimension:
Width 1030mm, Height 2090mm. Wing dimension:
Width 900mm, Height 2000mm.
12. Double wing fire door, with/without windows, model FW60 designation : fire door 1¼ hour (½, 1½, 1¼).Frame - Height 2394mm width 2359 mm,
Maximum dimension: Moveable wing - Height 2200mm,
Width 1140mm, Window - 400X600mm

This license is valid until 31/12/2025

Date of License : 01/01/2025



R.N 514160530

Dr. Gilad Golub
CEO



Annex A: License No. 42193

Factory: RAV-BARIACH (08) INDUSTRIES LTD

Commodities: Fire Door And Smoke Door Assemblies: Swinging Fire Doors

13. Double wing fire door, with/ without windows, model FW90-D with Counter lock designation : fire door 1½ hour (½,1½,1½). Frame - Height 2394mm
Frame - Height 2394mm width 2359 mm, dimension:
Moveable wing - Height 2200mm, Width 1140mm.
14. Double wing fire door, with/ without windows, model FW760 designation :fire door 1 hour (½,1¼,1)
Frame - Height 2227mm width 2300 mm dimension:
Moveable wing - Height 2200mm, Width 1140mm,
window - 400x600mm.
15. Double wing fire door, with/ without windows, model model FW770 designation : fire door 1½ hour (½, 1½, 1½). Frame - Height 2300mm width 2227 mm
dimension: Moveable wing - Height 2200mm,
Width 1140mm, window - 400x600mm.
16. Single wing fire door, without windows, model FE5F designation : fire door ½ hour (½, 1, ½).
Frame - Height 2210mm width 1100 mm, dimension:
wing: Height 2130mm, Width 980mm.

This license is valid until 31/12/2025

Date of License : 01/01/2025



R.N 514160530

Dr. Gilad Golub
CEO



Annex A: License No. 42193

Factory: RAV-BARIACH (08) INDUSTRIES LTD

Commodities: Fire Door And Smoke Door Assemblies: Swinging Fire Doors

17. Single /Double wing fire door,with/without windows
model FW780 designation :fire door $\frac{1}{2}$ hour ($\frac{1}{2}, 1\frac{1}{2}, \frac{1}{2}$)
Frame - Height 2400mm width 2227 mm,
Maximum dimension: Moveable wing - Height 2200mm,
Width 1140mm
18. Double wing fire door, with windows model : FW790
designation : fire door $\frac{1}{2}$ hour ($\frac{1}{2}, 1\frac{1}{2}, 1\frac{1}{2}$).
dimension :Frame : Height: 2367mm. width: 2227 mm.
dimension: Moveable wing : Height : 2200 mm,
Width :1140 mm, window : Width :400,Height :600 mm
19. Double egress fire door, without windows,
model: FW400, designation : fire door 2 hours
($\frac{3}{4} / 2 / 2$). dimension :Frame : Height :2290 mm
width: 2480 mm, dimension: Moveable wing :
Height : 2170 mm, Width :1170 mm.
20. Double wing fire door, with/without windows,
model FW765, designation : fire door $1\frac{1}{2}$ hour
($\frac{1}{2}, 1\frac{1}{2}, 1\frac{1}{2}$).
Frame : Height 2300mm, width 2368 mm.
Maximum dimension: Moveable wing - Height 2200mm,
Width:1140mm, Window: 400X600mm.

This license is valid until 31/12/2025

Date of License : 01/01/2025



R.N 514160530

Dr. Gilad Golub
CEO



Annex A: License No. 42193

Factory: RAV-BARIACH (08) INDUSTRIES LTD

Commodities: Fire Door And Smoke Door Assemblies: Swinging Fire Doors

21. Single wing fire door, with window, model FE5F-60.
designation: fire door 1 hour (3/4 / 1 / 1 1/4)
Frame dimension: Width 1280mm, Height 2305mm.
Wing dimension: Width 1140mm, Height 2305mm.
22. Single wing fire door, with window, model FE5F-45.
designation: fire door 3/4 hour (3/4 / 3/4 / 1 1/4)
Maximum Frame dimension: Width 1380mm, Height 2635 mm.
Maximum Wing dimension: Width 1240mm, Height 2530mm.
23. Fire / entrance door, single wing without a hatch with a fixed upper part. Made of sheet steel, model:438-30,
designation: fire door 1/2 hour (1/2 - 1/2 - 1 1/2)
Maximum Frame dimension: Width 1306mm, Height: 3000mm
Maximum Wing dimension: Width 1220mm, Height 2400mm.
24. Fire / entrance door, single wing without a hatch with a fixed upper part. Made of sheet steel, model:438-45,
Designation: fire door 3/4 hour (1/2 - 3/4 - 1 1/2)
Maximum Frame dimension: Width 1166mm, Height: 2794mm
Maximum Wing dimension: Width 1080mm, Height 2170mm.

This license is valid until 31/12/2025

Date of License : 01/01/2025



R.N 514160530

Dr. Gilad Golub
CEO



The standards Institution of Israel
42 Chaim Levanon St,
Tel-Aviv 6997701

היתר מספר 42193 לסמן מצרך בתו תקן

מכון התקנים הישראלי, בתוקף סמכותו לפי סעיף 11(ב) לחוק התקנים התשי"ג 1953 מעניק בזה ל:

רב בריח (08) תעשיות בע"מ

רח' החשמל 17, אשקלון

את הרשות לסמן בתו תקן את המצרכים שחל עליהם התקן שלהלן:
מכללי דלתות אש ומכללי דלתות עשן: דלתות אש סובבות

רשימת דגמים מצורפת

מצרכים אלה מיוצרים לפי דרישות התקן הישראלי ת"י 1212 חלק 1 מהדורה מאי 2003 ג"ת 1, 2, 3, 4, 5, 6

היתר זה ניתן בכפיפות לתנאים שבתקנות התקנים (תו-תקן וסימן השגחה), התשמ"ב 1982 ולתנאים שהחליטה עליהם ועדת ההיתרים, המהווים חלק בלתי נפרד מהיתר זה. היתר זה אינו גורע מכל חובה, או הוראה אחרת, המוטלת על פי דין על המצרכים הנ"ל. ההיתר הוא רכוש מת"י. לברור תוקף ההיתר ניתן לסרוק את הברקוד, או להיכנס לאתר מכון התקנים הישראלי www.sii.org.il

תוקף ההיתר עד יום 31/12/2025


ד"ר גלעד גולוב
מנכ"ל



פ. 514160530

תחילת תוקף היתר: 01/01/2025



מכון התקנים הישראלי



מכון התקנים הישראלי
רחוב חיים לבנון 42,
תל-אביב 6997701

נספח א' להיתר: 42193

מפעל: רב בריח (08) תעשיות בע"מ

מצרכים: מכללי דלתות אש ומכללי דלתות עשן; דלתות אש סובבות

דגמים:

1. דלת אש ממתכת חד כנפית עם/בלי צוהר מדגם 408
מידות מירביות של המלבן: רוחב 1,032 מ"מ,
גובה 2,200 מ"מ, שכינויה: דלת אש $\frac{3}{4}$ שעה ($\frac{1}{2}/\frac{3}{4}/1$)
2. דלת אש דו כנפית (ללא צוהר) מדגם 808
שכינויה: דלת אש $\frac{1}{2}$ שעה ($\frac{1}{2} / \frac{1}{2} / \frac{1}{2}$)
מידות כנף נעה: גובה 2185 מ"מ, רוחב 1180 מ"מ
מלבן: גובה 2300 מ"מ, רוחב 2200 מ"מ
3. דלת אש דו כנפית עם צוהרים, מדגם 808
שכינויה: דלת אש 1 שעה ($\frac{1}{2}/1/1$)
מידות מירביות:
כנף נעה: גובה 2185 מ"מ, רוחב 1180 מ"מ
מלבן: גובה 2198 מ"מ, רוחב 2197 מ"מ
4. דלת אש דו כנפית עם/בלי צוהרים מדגם FW90
שכינויה: דלת אש $1\frac{1}{2}$ שעה ($\frac{1}{2}/1\frac{3}{4}/1\frac{1}{2}$)
מידות מירביות: כנף נעה: גובה 2200, רוחב 1140 מ"מ
מלבן: גובה 2359 מ"מ, רוחב 2394 מ"מ
5. דלת אש דו כנפית עם/בלי צוהרים מדגם FW30
שכינויה: דלת אש $\frac{1}{2}$ שעה ($\frac{1}{2}/1\frac{1}{2}/\frac{1}{2}$)
מידות מירביות: כנף נעה: גובה 2250, רוחב 1140 מ"מ
מלבן: גובה 2300 מ"מ, רוחב 2360 מ"מ

תוקף ההיתר עד יום 31/12/2025


ד"ר גלעד גולוב
מנכ"ל



פ. 514160530

תחילת תוקף היתר: 01/01/2025

עמוד 2 מתוך 7



מכון התקנים הישראלי
רחוב חיים לבנון 42,
תל-אביב 6997701

נספח א' להיתר: 42193 מפעל: רב בריח (08) תעשיות בע"מ

מצרכים: מכללי דלתות אש ומכללי דלתות עשן; דלתות אש סובבות

6. דלת אש חד כנפית עם/בלי צוהרים מדגם FWB שכינויה 3/4 שעה, סיווגה: (1/2 / 3/4 / 1 1/2) מידות מירביות:
כנף - גובה 2255 מ"מ, רוחב 980 מ"מ
מלבן - גובה 2307 מ"מ, רוחב 1054 מ"מ
7. דלת אש ממתכת חד כנפית עם/בלי צוהר מדגם FWI-870 שכינויה 3/4 שעה בסיווג (1/2 / 1 1/2 / 3/4) מידות מלבן: רוחב 1210 מ"מ, גובה 2400 מ"מ
מידות אגף: רוחב 1140 מ"מ, גובה 2200 מ"מ
8. דלת אש חד אגפית מדגם 408 מ' שכינויה דלת אש 1/2 שעה (1/2, 1/2, 1/2) מידות מלבן מירביות: רוחב 1030 מ"מ, גובה 2270 מ"מ
מידות אגף מירביות: רוחב 960 מ"מ, גובה 2210 מ"מ
9. דלת אש דו-כנפית מבוקרת עם/בלי צוהרים מדגם FWI-870 שכינויה 1 שעה (1 / 1 1/2) מידות מירביות: מלבן- רוחב 2359 מ"מ, גובה 2295 מ"מ
כנף נעה-רוחב 1140 מ"מ, גובה 2200 מ"מ
10. דלת אש דו אגפית עם/בלי צוהרים מדגם FW30 משופרת שכינויה דלת אש שעה וחצי (1/2 / 2 / 1 1/2) מידות מלבן מירביות: רוחב 2360 מ"מ, גובה 2300 מ"מ
מידות כנף נעה מירביות: רוחב 1140 מ"מ, גובה 2050 מ"מ

תוקף ההיתר עד יום 31/12/2025


ד"ר גלעד גולוב
מנכ"ל



פ. 514160530

תחילת תוקף היתר: 01/01/2025

עמוד 3 מתוך 7



מכון התקנים הישראלי
רחוב חיים לבנון 42,
תל-אביב 6997701

נספח א' להיתר: 42193

מפעל: רב בריח (08) תעשיות בע"מ

מצרכים: מכללי דלתות אש ומכללי דלתות עשן; דלתות אש סובבות

11. דלת אש חד אגפית (ללא צוהר) מדגם FE15 שכינוייה: דלת אש 1 שעה (1/2/1/1) מידות מלבן: רוחב 1030 מ"מ, גובה 2090 מ"מ מידות כנף: רוחב 900 מ"מ, גובה 2000 מ"מ
12. דלת אש דו אגפית עם/בלוי צוהרים מדגם: "FW60" שכינוייה: דלת אש 1¼ שעה (1/2/1½/1¼) מידות המלבן רוחב 2359 מ"מ, גובה 2394 מ"מ מידות אגף פעיל: רוחב: 1140 מ"מ, גובה 2200 מ"מ מידות צוהרים: 600X400 מ"מ
13. דלת אש דו-אגפית (עם צוהרים) דגם FW90-D עם מנעול נגדי שכינוייה: דלת אש 1½ שעה (1/2/1½/1½) מידות אגף פעיל: רוחב 1140 מ"מ, גובה 2200 מ"מ מידות מלבן: רוחב 2359 מ"מ, גובה 2394 מ"מ
14. דלת אש דו-אגפית (עם צוהרים) מדגם "FW-760" שכינוייה: דלת אש 1 שעה (1/2/1¼/1) מידות מלבן: רוחב רוחב 2300 מ"מ, גובה 2227 מ"מ מידות אגף פעיל: רוחב 1140 מ"מ, גובה 2200 מ"מ מידת צוהרים: 400X600 מ"מ

תוקף ההיתר עד יום 31/12/2025


ד"ר גלעד גולוב
מנכ"ל



פ.ח. 514160530

תחילת תוקף היתר: 01/01/2025



מכון התקנים הישראלי
רחוב חיים לבנון 42,
תל-אביב 6997701

נספח א' להיתר: 42193

מפעל: רב בריח (08) תעשיות בע"מ

מצרכים: מכללי דלתות אש ומכללי דלתות עשן; דלתות אש סובבות

15. דלת אש דו אגפית עם צוהר מדגם FW770 שכינוייה:
דלת אש 1½ שעה (½, 1½, 1½)
מידות מלבן: רוחב: 2227 מ"מ, גובה: 2300 מ"מ
מידות אגף: רוחב אגף פעיל: 1140 מ"מ, גובה: 2200 מ"מ
מידות צוהר: 600X400 מ"מ
16. דלת אש חד אגפית (ללא צוהר) מדגם FE5F, שכינוייה: דלת
אש ½ שעה (½, 1, ½)
מידות מלבן: רוחב: 1100 מ"מ, גובה: 2210 מ"מ.
מידות אגף: רוחב: 980 מ"מ, גובה: 2130 מ"מ.
17. דלת אש חד/דו אגפית (עם/ בלי צוהרים) מדגם "FW 780",
שכינוייה: דלת אש ½ שעה (½ / 1½ / ½), מידות אגף:
רוחב-אגף פעיל: 1140 מ"מ, גובה: 2200 מ"מ, מידות
מלבן: רוחב: 2227 מ"מ, גובה: 2400 מ"מ
18. דלת אש דו כנפית עם צוהרים דגם: FW790,
שכינוייה: דלת אש 11/2 שעה (1/2-11/2-11/2).
מידות אגף פעיל: רוחב: 1140 מ"מ, גובה: 2200 מ"מ.
מידות מלבן: רוחב: 2227 מ"מ, גובה: 2367 מ"מ.
מידות צוהרים: רוחב: 400 מ"מ, גובה: 600 מ"מ.

תוקף ההיתר עד יום 31/12/2025


ד"ר גלעד גולוב
מנכ"ל



פ. 514160530

תחילת תוקף היתר: 01/01/2025



מכון התקנים הישראלי
רחוב חיים לבנון 42,
תל-אביב 6997701

נספח א' להיתר: 42193 מפעל: רב בריח (08) תעשיות בע"מ

מצרכים: מכללי דלתות אש ומכללי דלתות עשן; דלתות אש סובבות

- .19 דלת אש כפולת מוצא, ללא צוהרים מדגם: FW400, שכינוייה: דלת אש שעתיים (3/4-2-2). מידות מלבן מירביות: רוחב: 2480 מ"מ, גובה: 2290 מ"מ, מידה מירבית של אגף אקטיבי: רוחב: 1170 מ"מ, גובה: 2170 מ"מ
- .20 דלת אש דו אגפית עם/בלי צוהרים מדגם: FW765 שכינוייה: דלת אש שעה וחצי (1/2/1 1/2/1 1/2) מידות מלבן: רוחב: 2368 מ"מ, גובה: 2300 מ"מ מידות אגף אקטיבי: רוחב: 1140 מ"מ, גובה: 2200 מ"מ מידות צוהר: 600X400 מ"מ
- .21 דלת אש חד אגפית עם צוהר מדגם: FE5F-60 שכינוייה: דלת אש 1 שעה (3/4-1-1 1/4) מידות מלבן: רוחב 1280 מ"מ, גובה: 2305 מ"מ מידות אגף: רוחב 1140 מ"מ, גובה: 2305 מ"מ
- .22 דלת אש חד אגפית עם צוהר מדגם: FE5F-45 שכינוייה: דלת אש 3/4 שעה (3/4-3/4-1 1/4) מידות מרביות מלבן: רוחב: 1380 מ"מ, גובה : 2635 מ"מ מידות מרביות אגף: רוחב: 1240 מ"מ, גובה: 2530 מ"מ

תוקף ההיתר עד יום 31/12/2025


ד"ר גלעד גולוב
מנכ"ל



פ.ח. 514160530

תחילת תוקף היתר: 01/01/2025

עמוד 6 מתוך 7



מכון התקנים הישראלי
רחוב חיים לבנון 42,
תל-אביב 6997701

נספח א' להיתר: 42193 מפעל: רב בריח (08) תעשיות בע"מ

מצרכים: מכללי דלתות אש ומכללי דלתות עשן; דלתות אש סובבות

23. דלת אש/כניסה חד אגפית ללא צוהר עם חלק קבוע עליון

העשוי מפח פלדה, מדגם: 438-30

שכינוייה: דלת אש 1/2 שעה (1/2-1/2-11/2)

מידות מרביות מלבן: רוחב: 1306 מ"מ, גובה: 3000 מ"מ

מידות מרביות אגף: רוחב: 1220 מ"מ, גובה: 2400 מ"מ

24. דלת אש/כניסה חד אגפית ללא צוהר עם חלק קבוע עליון

העשוי מפח פלדה מדגם: 438-45

שכינוייה: דלת אש 3/4 שעה (1/2-3/4-11/2)

מידות מרביות מלבן: רוחב: 1166 מ"מ, גובה: 2794 מ"מ

מידות מרביות אגף: רוחב: 1080 מ"מ, גובה: 2170 מ"מ



מכון התקנים הישראלי

תוקף ההיתר עד יום 31/12/2025


ד"ר גלעד גולוב
מנכ"ל



פ.ח. 514160530

תחילת תוקף היתר: 01/01/2025

עמוד 7 מתוך 7



מכון התקנים הישראלי
רחוב חיים לבנון 42,
תל-אביב 6997701